

---

# **Calibration Devices CDMR & Progress Status**

# Calibration devices of NectarCAM



## Flat-field light source

At the center of the dish

Aim: relative gain of all PMTs

## Focal-plane calibration device

In NectarCAM (between PMTs & window)

Aims:

- on-/off-axis point spread function
- absolute gain of each PMT

---

**CDMR outcome**

---

# Overview of RIXs

---

## **Ten RIXs to be addressed**

Most of them can be addressed in April - May

Main possible blocking point (see next slides): dark room time for flat-field characterization

## **Nine normal priority RIXs**

3 normal-priority RIXs require email exchanges:

- unclear proposed actions to be followed up for 2 RIXs (42563, 42735)
- hazard analysis in cooperation with K. Tegel (42727) to be followed up by RAMS?

6 normal-priority RIXs with text updates (42622, 42959, 42732, 42734, 42855, 42988)

→ will be swiftly addressed with minor updates of the documentation text

## **One high-priority RIX (42556)**

Finalization of V04 flat-field flasher:

- Mechanical upgrade proposed following Adleshorf campaign (this RIX was expected)
- Action items proposed by panel in line with planned actions at LUPM & IJCLab

Open item to be discussed: electronics updates suggested by panel (see next slides)

# Normal priority RIXs

---

## Text updates

DD183 internal FFCLS interface: 42622 - AI (JB): "rename the document to indicate that it includes the laser specifications"

FFCLS User Manual 42959 - AI (PB-KP): briefly describe control and diagnostics, supplement maintenance & software upgrade sections, even if not complete

FPCD stress and durability test: 42732 - AI (KP-JB): justify XY table random motion test duration

→ Comment on this RIX (*to Oscar*): "A combined structural analysis of the NectarCAM + structure shall be done as a design verification of the overall MST, that is not in the scope of the NectarCAM CDMR."

FPCD RAMS & Obsolescence: 42734 - AI (KP): update the text indicating that providers of off-the-shelf component have been carefully identifying to guarantee long-term provision + remove mention to RAMS analysis

DD197 FPCD perf. vs req.: 42855 - AI (KP-MJ): minor specific updates suggested by panel member to be added

FPCD User Manual: 42988 - AI (KP-PB): briefly describe control and diagnostics, supplement maintenance and operation sections

## Email exchanges needed

Missing reference standard FFCLS: 42563 - AI (JB): contact Francesco Dazzi → unclear proposed action to be followed up

FPCD classification: 42735 - AI (JB): contact Francesco Dazzi → unclear proposed action to be followed up

FPCD safety system: 42727 - AI (JB): discuss with Stephane: "The proposed action is to develop a hazard analysis and a risk assessment in cooperation with the safety engineer (K. Tegel). Then, you have assess if the current design satisfies the EU product safety requirements."


# High priority RIX: flat-field new design to be tested

## Upgrades wrt Adlershof


*Mechanics V03 → V04 outlined in CDMR doc DD187*

- **Laser alignment system** ( $\delta\theta < \text{pixel}$ )
- **Engineered diffusive window** (flatness within 2%)  
*Note: better than requirement = pattern known within 2%*
- **Associated mechanical enclosure**

**Mechanics V03**



**Mechanics V04**



## Upgrades suggested by CDMR panel

- Spare fiber connector: **implemented**
- Humidity sensor + Power-surge / Lightning protection:  
→ AI CTAO: decide if Power-surge / Lightning protection improvements to be mandated.  
→ Better course of action, AI JB: contact Markus to determine if such protections are applied to other components in the center of the MST dish

## Timeline

- April 2021: **IP67 waterproofness** of V04 enclosure
- By spring 2021: **Illumination vs  $\theta(^{\circ})$  &  $T(^{\circ}\text{C})$**  in IRFU dark room  
→ **Highest priority (IRFU-IJCLab-LUPM): pre-summer timeslot for angular measurements**



---

**Calibration devices: status**

---

# Flat-field calibration light source: electronics

---

Electronics design unchanged 

## Main open item: high-priority RIX


Addition of power-surges and humidity sensor. Based on Markus's feedback on other central-dish components:

- Either discuss lightning protection standards with CTAO, implement upgrades, re-implement IPC Class 3 routing
- Or do not implement any of the change and validate this with CDMR panel



# Flat-field calibration light source: mechanics

Alignment system ✓



Procurement & manufacturing ✓



IP67 Waterproofness: to be done in April



2% flatness + temperature: dark-room timeslot



# Focal-plane calibration device: overview

## Electronics design unchanged ✓

IPC Class 3 routing launched

*Note: not implemented for 2 pairs of SPE boards at IRAP*

## XY automatics design unchanged ✓

TBD: test MCB with NectarCAM OPC-UA architecture

## XY mechanics design unchanged ✓

Done: X motorization installed on NectarCAM

Integration TBD: transverse Y rail, SPE screen, MCB

Testing TBD: realistic tests with camera structure

## Dip coating reproducibility ✓

Improvement of SPE screen optical performance (see next slide)





Fig. 2: Front view of the NectarCAM camera with the focal plane calibration device in parking position

# Focal-plane calibration device: optics

## Characterization of properties of paint layers

Density, viscosity and surface tension vs dilution

Impact of temperature, lift-up and dip-down speed on thickness




## 10-15 paintings tested over the past year

Nice improvement of the lateral profile wrt Adlershof screen

Minor room for improvement on longitudinal profile ( $\neq v(\text{lift})$  for  $\neq$  layers)

Reproducibility: all area covered within max/4-5



# Focal-plane calibration device: SPE scan

## Optimization of scan procedure


Less than 60 successive positions

Estimated duration: **15-30 min**

- Transit time from one position to another: 10-15 s
  - DACQ time per position: 10s at 1 kHz
- to be validated on NectarCAM

## Ongoing software work

Association of screen position with relevant PMTs during scan



---

## Summary

---

# Tentative planning & Critical items

